

FIRE DAMAGED FACILITIES- 08/04/00

TA	BLDG	NAME	OPERATIONAL STATUS
0	480	Pajarito School	Possible friable asbestos; custodial
3	16	Ion Beam Facility	Need chain link fence south side replaced.
3	30	Warehouse	Replace filters
3	31	Chem Warehouse	Replace filters
3	39	Tech Shops	Sprinkler damage; some electrical disconnected
3	43	Administration Bldg.	Replace AC filters; replace filters on HVH units; clean supply air ducts clean
3	65	Source Storage Bldg	windows; clean strainers on cooling tower lines; custodial cleaning; carpets
3	97	Guard Station	Filters, window, handrails
3	100	Office Building	Replace filters; custodial; remove debris
3	102	Office Building	HVAC and swamp cooler filter replacement; general custodial cleanup
3	102	Tech Shops Addtn	Sprinkler damage, some electrical disconnected
3	142	Warehouse	Replace HVA filters
3	164	S-Div Warehouse	Need large swamp cooler filter replacement
3	170	Liq & Comp Gas	Replace HVA filters; clean carpet; custodial; remove debris
3	215	Physics Analy Ctr	Broken window
3	261	Otowi	Filter replacement, air wash piping, equipment clean up, air wash water treatment
3	373	Guard Station #415	Replace filters; custodial; remove debris
3	409	Occup Health	HVAC and swamp cooler filter replacement; general custodial cleanup
3	410	Office Building	Replace swamp cooler filters (6)
3	440	CAS	Need filter replacement
3	443	University House	HVAC and swamp cooler filter replacement; general custodial cleanup
3	452	Office Building	Replace filters
3	456	Transportable	Replace swamp cooler filters (3)
3	468	Transportable	Need swamp cooler filter replacement
3	470	Trans Office	Need swamp cooler filter replacement
3	474	Trans Office	Need swamp cooler filter replacement
3	490	Badge Office	Replace HVA filters; clean carpet; custodial; remove debris
3	495	Transportable	Need swamp cooler filter replacement
3	496	Transportable	Need swamp cooler filter replacement
3	512	Transportable	Need HVAC filter replacement (3)
3	513	Transportable	Need HVAC filter replacement (3)
3	514	Transportable	Need HVAC filter replacement (3)
3	566	Transportainer	Fire hydrant #506 is leaking
3	1353	Transportable	Need swamp cooler filter replacement
3	1544	Trailer Office	Inside door broken on Rm. 101
3	1549	Office	Replace HV filters
3	1550	Office	Replace HV filters
3	1616	Transportable	HVAC and swamp cooler filter replacement; general custodial cleanup
3	1617	Transportable	HVAC and swamp cooler filter replacement; general custodial cleanup
3	1635	Occup Health	HVAC and swamp cooler filter replacement; general custodial cleanup
3	1636	Occup Health	HVAC and swamp cooler filter replacement; general custodial cleanup
3	1663	Wellness Center	Replace swamp cooler filters; boiler restart (2)
5	46	SVC Control Bldg	Damaged
6	80	Morgan Shed	Destroyed
6	114	Military Shelter	Custodial- Walls. Burned interior.
8	21	Lab & Office Bldg	Damaged glass, carpet, walls, replace filters
9	21	Lab & Office Bldg	Fire panel showing trouble; need filters replaced; custodial - walls, carpet
9	28	Shop Bldg	Custodial - walls, carpet
9	29	Stock & Equip Bldg	Custodial - walls, carpet; reset fire alarm
9	32	Magazine	Custodial
9	33	Lab Bldg	Custodial - walls, carpet
9	34	Process Lab	Custodial - walls, carpet; no communications
9	35	Process Lab	Custodial - walls, carpet
9	40	Environmental Chamber	Phone lines need repair, custodial
9	42	Process Lab	Custodial - walls, carpet
9	43	Process Lab	Custodial - walls, carpet
9	45	Process Lab	Custodial - walls, carpet
9	46	Storage Bldg	Custodial - walls, carpet
9	50	Receiving & Shipping	Custodial - walls, carpet; verify no damage from overheating of storage area
9	51	Environmental Test Chamber	Damaged
9	208	Day Magazine	Custodial
9	272	Transportable	Custodial
9	282	Boiler Bldg	Custodial-minor soot
11	25		Damaged per Facility Manager
11	56	Transportainer	Outside paint damage
14	5	Bunker	Destroyed
14	23	Control Bldg	Phone service needs repair, custodial.
14	34	Control Bldg	Custodial
14	43	Assembly and Storage Bldg	Phone service needs repair, custodial.
14	69	Semi-trailer	Phone service needs repair, custodial.
15	8	Storage Bldg	Roof - part of roof detached on the ground, possible friable asbestos; outside doors burned

FIRE DAMAGED FACILITIES- 08/04/00

TA	BLDG	NAME	OPERATIONAL STATUS
15	20	Metal Storage/Process	Partial Damage
15	40	Lab & Office Bldg	Fire panel needs repair; Custodial, walls, carpets
15	50	Staff Shop	Destroyed. See Inspection of Damage Report attached to the Safety Recon Form.
15	183	Lab & Office Bldg	Repair 2 exterior doors; custodial, walls, carpets
15	184	PHERMEX Chamber/Amp	Replace all filters; communications not working;custodial
15	194	Metal Storage/Process	Partial Damage
15	203	Metal Storage/Process	Partial Damage
15	213	Metal Storage/Process	Partial Damage
15	239	Passageway	Destroyed
15	245	Metal Storage/Process	Partial Damage
15	261	Oil Storage Tank	Damaged by fire. Turned over to D&D
15	263	Laboratory Bldg	Filter replacement; custodial
15	280	Ector Diode Prep Lab	No Communications
15	305	Transportable	Custodial, walls, carpets
15	306	Multi-diag Hydotest Fac	No communications
15	310	Multi-diag Operations Bldg	Custodial
15	313	Radiographic Supply Lab	Custodial - walls, carpets
15	314	Metal Shed	Destroyed
15	329	Transportable	Damaged by fire. Turned over to D&D
15	332	Transportainer	Pest control
15	333	Transportainer	Pest control
15	334	Transportainer	Pest control
15	335	Transportainer	Pest control
15	336	Transportainer	Pest control
15	337	Transportainer	Pest control
15	339	Shed	Destroyed
15	356	Transportainer	Pest Control
15	371	Transportainer	Destroyed
15	372	Transportainer	Destroyed
15	373	Transportable	Damaged by fire. Will be turned over to D&D
15	374	Metal Shed	Damaged by fire. Will be turned over to D&D
15	375	Transportable	Destroyed
15	446	Firing Access Control	Custodial - walls, carpets; repair phone lines
15	447	Trailer	Damaged - SW corner of skirting melted; drainline on north side is collapsed
15	448	Trailer	Destroyed. Damaged - south side of building suffered heat damage-PVC skirting melted; windows broken due to heat and melting of gasket; telephone wiring melted; electrical wiring of questionable integrity
15	454	Transportainer	Pest control
15	456	Transportable	Damaged - broken windows; custodial - walls, carpets
15	465	Trailer	Custodial cleaning; stairs need fixing
15	468	Office Trailer	Damaged - trailer skirting melted; replace filters; custodial
15	476	Office Trailer	Damaged trailer skirt, custodial
15	480	Transportainer	Destroyed
15	484	Hydro Dynamic Test Ops	HVAC system controls not functional; smoke detector inside duct not functional; ductwork may have significant smoke particulates; roof damage, northeast corner; hole in wall
15	488	Shed	Destroyed
15	494	Trailer - AROE	Custodial - walls, carpets; verify no impact on building construction
16	54	Instrumentation/Testing	Fire alarm panel indicates alarm condition.
16	207	Warehouse	Damage - Custodial, HVAC
16	251	Trailer	Custodial; communications; lights
16	261	Rest House	Damaged prior to fire
16	300	Inert Prep Bldg	Broken windows, possible cable damage.
16	302	Process Bldg	Broken windows in corridors. Cable damage and alarm sounding.
16	303	Rest House	Cracked windows in corridors. Phones are not working.
16	305	Plastics Bldg	Possible cable damage.
16	308	Process Bldg	Cable damage.
16	319	Office	Cable damage.
16	340	Explosives Synthesis	Fire alarm trouble.
16	410	Assembly Bldg	Damaged
16	413	Rest House	Damaged - ash, EXTX potentially damaged
16	415	Rest House	Damaged - ash, EXTX potentially damaged
16	435	Rest House	Damaged - ash, EXTX potentially damaged
16	515	Process Bldg	Destroyed Total Loss
16	518	Storage Bldg	Destroyed Total Loss
16	519	Storage Bldg	Destroyed Total Loss
16	520	Test Bldg	Destroyed Total Loss
16	524	Office Building	Destroyed Total Loss
16	559	SEA Van	Destroyed Total Loss
16	578	Transformer Station	Destroyed Total Loss
16	1385	Transportainer	Electrical is out
16	1483	Steam Plant #4	Damaged - south side scorched, remove trees

FIRE DAMAGED FACILITIES- 08/04/00

TA	BLDG	NAME	OPERATIONAL STATUS
16	1485	Steam Plant #6	Damaged - side scorched, remove trees
16	0016-019	MDAR R	This site is smoldering. There will be no activity on this site until fire protection confirms fire is out.
22	5	Warehouse/Plastics Shop	Pest Control
22	18	Magazine	Destroyed. Burned over berm. Lightning rod/telephone pole destroyed. Lightning protection system damaged.
22	34	Laboratory Bldg	Check filters; custodial; pest control
22	52	Shops Bldg	Replace filters; broken window Room 107; clean refrigerator
22	90	Office Building	Partial Damage - walls, carpet
22	91	Detonator Facility	Custodial - walls, carpets; clear FP system trouble alarm
22	93	High Explosive Wing	Custodial - walls, carpets; fix leaking fire hydrant
22	94	Concrete/Earthen Berm	Custodial
35	189	Optics Eval Lab	Water damage to Trident Laser Hall - ceiling, walls, lighting fixtures, programmatic equipment; smoke damage to laser optics; repair HVAC system
36	54	Metal Shed	Filters replaced. Check Roof
39	2	Lab Office	Custodial - walls, carpets; no phone service
39	62	Storage Bldg	Custodial - walls, carpets; no phone service
39	103	Transportable	Custodial - walls, carpets; no phone service
39	107	Transportable	Custodial - walls, carpets; no phone service
40	1	Lab/Office Bldg	Communications; custodial; windows
40	4	Firing Point	Damaged -damaged poles, overhead structures, no power
40	5	Firing Point	Damaged
40	23	Machine Shop	Damaged - roof, water, communications; custodial
40	40	Bunker	Roof ventilation damaged. Security lighting pole #09 charred. Hydrogen peroxide trailer burned.
40	43	Storage Bldg	Roof Damage
40	72	Wood Storage	Destroyed
40	73	Wood Storage	Destroyed
40	90	Transportable	Replace filters; Custodial; Communication lines damaged
40	Vehicles		Damaged
43	49	Safety Storage Shed	Custodial - walls, carpet
46	1	Lab/Office Bldg	Flooding, salvage area burned
46	31	Test Bldg #2	North wall damaged, filters
46	42	Lab/Office Bldg	Smoke damage, possible damage to electronics
46	86	Cooling Tower	Destroyed
46	87	Pump House	Destroyed
46	120	Modular Office Bldg	25% Loss
46	121	Transportable	Destroyed including 4 vehicles
46	154	Phys Chem Lab	Damaged
46	158	Laser Induced Chemistry Lab	Replace filters; custodial, fans making loud noises
46	181	Trailer	Destroyed
46	195	Modular Solar House	Damaged - ash, odors, filters
46	204	Transportable	Damaged - ash, odors, filters
46	217	Transportable	Damaged
46	218	Transportable	Damaged - filters, carpets, possible utilities damage
46	241	Trailer	Destroyed
46	242	Trailer	Destroyed
46	307	Transportainer	Damaged - burnt north & east sides, blocking burnt east side
46	325	Trailer	Destroyed
46	326	Tech Supp Fac	Damaged
46	397	Trailer	Destroyed
46	451	Shed	Pest Control
46	463	Transportainer	20% Loss
48	26	Office Building	Replace Filters, cleaning
48	33	Transportable	Replace Filters, cleaning
48	45	Clean Chem/Mass	Damaged
48	56	Transportable	Damaged-roof
48	57	Transportable	Damaged-roof
48	203	Doublewide Trailer	Damaged - skirting North side melted, insulation
49	113	Haz Dev Team Training	Replace HVA and swamp cooler filters
52	1	Lab & Office Bldg	Damaged - replace filters (32), custodial, carpets, walls, floors
52	35	Transportable	Replace filters (2); swamp cooler pads (8); custodial - carpets, walls, exterior
52	36	Transportable	Replace filters (2); swamp cooler pads (8); custodial - carpets, walls, exterior
52	111	Trailer	Destroyed
54	33	Tru-waste Drum	Damaged - door
54	1005	Office Trailer (ESH-17)	Slight damage to skirting on NE corner of building
59	1	Occup Health	Replace filters (12); custodial, carpets, walls, exterior housekeeping
59	2	Modular Office Bldg	Replace filters (4); custodial, carpets, walls, exterior housekeeping; replace cable to monitor
59	3	ESH-DO	Replace filters (12); custodial, carpets, walls, exterior housekeeping
59	29	Morgan Shed	Replace filters (3), replace swamp cooler pads (12); custodial, carpets, walls , exterior housekeeping

FIRE DAMAGED FACILITIES- 08/04/00

TA	BLDG	NAME	OPERATIONAL STATUS
59	30	Transportable	Replace filters (3), replace swamp cooler pads (12); custodial, carpets, walls , exterior housekeeping
59	31	Transportable	Replace filters (3), replace swamp cooler pads (12); custodial, carpets, walls , exterior housekeeping
59	32	Transportable	Replace filters (3), replace swamp cooler pads (12); custodial, carpets, walls, exterior housekeeping
59	33	Transportable	Replace filters (3), replace swamp cooler pads (12); custodial, carpets, walls, exterior housekeeping
59	34	Transportable	Replace filters (3), replace swamp cooler pads (12); custodial, carpets, walls, exterior housekeeping
59	35	Transportable	Replace filters (3), replace swamp cooler pads (12); custodial, carpets, walls, exterior housekeeping
59	36	Transportable	Replace filters (3), replace swamp cooler pads (12); custodial, carpets, walls, exterior housekeeping
59	37	Transportable	Replace filters (3), replace swamp cooler pads (12); custodial, carpets, walls, exterior housekeeping
59	53	Transportable	Damaged - replace filters (3), swamp cooler pads; custodial, carpets, walls, floors
59	96	Transportable	Damaged - replace filters (3), swamp cooler pads; custodial, carpets, walls, floors
59	97	Transportable	Damaged - replace filters (3), swamp cooler pads; custodial, carpets, walls, floors
59	116	Transportable	Replace filters (2); custodial, carpets, walls, exterior housekeeping
59	117	Transportable	Replace filters (2); custodial, carpets, walls, exterior housekeeping
59	118	Trailer	Replace filters (2); custodial, carpets, walls, exterior housekeeping
59	119	Transportable	Replace filters (2); custodial, carpets, walls, exterior housekeeping
59	123	Trailer	Replace filters (2); custodial, carpets, walls, exterior housekeeping
60	20	Trailer	Broken window; custodial
60	94	Semi-trailer	Damaged - exterior damage to trailer
64	1	PTLA (Central Guard Facility)	Damaged - exterior of building, custodial, filter replacement
64	7	Morgan Shed	Destroyed
64	9	Trailer	Destroyed, Total Loss
64	11	Military Shelter	Destroyed
64	12	Military Shelter	Destroyed
64	13	Military Shelter	Destroyed
64	14	Portable Army Shelter	Destroyed
64	15	Military Shelter	Destroyed
64	17	Transportainer	Destroyed
64	18	Transportainer	Destroyed
64	19	Morgan Shed	Destroyed
64	20	Transportainer	Destroyed Total Loss
64	21	Transportainer	Destroyed
64	23	Morgan Shed	Destroyed
64	24	Military Shelter	Destroyed
64	27	Trailer	Damaged - filters, skirting
64	37	Morgan Shed	Destroyed Total Loss
64	39	Hazardous Materials Response	Damaged - filter replacement, custodial, carpets, walls
64	43	Tension Support Dome	Damaged
69	2	Doublewide Trailer	Damaged - smoke/heat damage to exterior walls, nails bucked out of wood
72	39	Firing Range Admin	Rm 108 (computer room) needs to be cleaned